



LIGHTING WIRING NOTES:

1. PROVIDE WIRING TO ALL LIGHTING FIXTURES FROM PANEL LG UNLESS SHOWN OTHERWISE.
2. PROVIDE TWO CIRCUITS TO EACH EXIT SIGN. NORMAL POWER TO BE AN UNSWITCHED LEG OF THE CIRCUIT SERVING THE AREA.
3. ROOMS WITH ONE SWITCH IN ROOM, SWITCH SERVES ALL FIXTURES IN ROOM.
4. PROVIDE RACEWAY AND CONDUCTORS TO EACH LIGHT FIXTURE. SHOW ROUTING AND CONDUCTORS ON RECORD AS-BUILT DRAWINGS.

POWER WIRING NOTES:

1. RECEPTACLE CIRCUIT WIRING FROM PANEL G UNLESS NOTED OTHERWISE.
2. PROVIDE EACH RECEPTACLE WITH 2#12, #20 AND #20C SEPARATE, UNSHARED WITH OTHER CIRCUITS.

FLAG NOTES:

1. SEE ONE LINE DIAGRAM.
2. LIGHTING CIRCUITS ARE FROM PANEL LG UNLESS SHOWN OTHERWISE. ALL WIRING #10 AWG.
3. RECEPTACLE CIRCUITS THIS PLAN ARE FROM PANEL G UNLESS SHOWN OTHERWISE. ALL WIRING #10 AWG, UNLESS SHOWN LARGER.
4. PROVIDE RELAY AND ASSOCIATED WIRING FOR EACH SWITCHLEG SHOWN. SEE DRAWINGS E7, E8, E9.
5. PROVIDE PRIMARY DUCT ENTRANCE PER PUCET POWER.

SECT. 1	SECT. 2	SECT. 3	SECT. 4
PANEL 4G	A 15 HP B 15 HP C 3/4 HP D 30 HP	A 3/4 HP B 2 HP C 2 HP D 2 HP	A 3/4 HP B 2 HP C 2 HP D 2 HP
STCB	E 1 HP F 30 HP	AHU-9 AHU-10	AHU-9 AHU-10

NOTE: SEE DRAWING E4A FOR RACEWAY SYSTEM LOCATED AT GARAGE LEVEL CEILING.

Jan 31, 1992 - 10:25:48 2208/3/92

DATE: FEBRUARY 3, 1992

DESIGN: Department

TECHNICAL: Department

JOB: Casata

DRAWN: Ry

REVISION NO. 2/3/92 BID DOCUMENTS

ARCHITECTURE/PLANNING/INTERIOR DESIGN

ZIMMER-GUNSUL-FRASCA PARTNERSHIP

Seattle

NEUPORT BEACH

PLAN - LOWER LEVEL ELECTRICAL

BELLEVUE LIBRARY

KING COUNTY LIBRARY SYSTEM

SPARLING

JOB NO. 4030-01

E3

07 Sheets